



Bar No.	Bar Size	Bar Spacing	Bar Length	Bar Quantity	Bar Weight	Bar Notes
1	#3	16"	16"	16"	16"	
2	#4	16"	19"	16"	16"	
3	#5	19"	24"	16"	19"	
4	#6	25"	31"	17"	23"	
5	#7	39"	51"	25"	33"	
6	#8	48"	63"	30"	39"	
7	#9	59"	76"	35"	46"	
8	#10	69"	90"	41"	52"	
9	#11	82"	107"	51"	67"	

LAP SCHEDULE, GR. 60 (9800PSI)

BAR SIZE	SLAB	TOP	BEAMS	TOP
#3	16"	16"	16"	16"
#4	16"	19"	16"	16"
#5	19"	24"	16"	19"
#6	25"	31"	17"	23"
#7	39"	51"	25"	33"
#8	48"	63"	30"	39"
#9	59"	76"	35"	46"
#10	69"	90"	41"	52"
#11	82"	107"	51"	67"

NOTES:
 1) ALL BOTTOM REINF. AT 12" O.C. U.O.A.
 ALL SLABS ARE 12" U.O.A.
 PROVIDE 1/2" CLR. COVER FOR #5 BAR SMALLER.
 2) GRADE 60 FOR ALL BARS.
 * DENOTES ADD'L REINF. & ALL WITH MAIN BARS
 ** DENOTES 2 ADD'L BETW. 2 MAIN BARS

DATE: _____ SENT FOR: _____

Cross Country Construction LLC
 3 WESTMAN STREET SUITE 104 BILMOR, NY 10523
 PHONE 914.909.6700 FAX 914.592.3000

DWG. AREA: 7TH FLOOR SLAB BEAMS AND BOTTOM BARS

JOB: _____

LOCATION: NEW YORK, NY

ARCHITECT: _____

ENGINEER: _____

DRAWN BY: JGL DWG. No. _____